

Certificate

Sanitary components

Family of products: WATER

CSTB hereby certifies that the products referred to in the appendix comply with the characteristics described in the certification reference system Sanitary components (NF 076), in force, following an assessment performed according to the inspection procedures set out in this reference system.

By virtue of the present decision notified by CSTB, AFNOR Certification grants:

The company **SOCIETE SIAMP**
1 RUE DE GABIAN IMMEUBLE LE THALES
BP 219
MC-MC-98001 MONACO

Factory : **VN- Ho Chi Minh**

the right to use the NF mark Sanitary components for the products covered under this decision, throughout its period of validity and under the conditions provided for in the general rules of NF mark and the above-mentioned reference system.

Decision of renewal n° 269-U2-21/5 dated 04/05/2021
This decision replaces decision n° 269-U2-21/4 dated 26/04/2021

Except in case of withdrawal, suspension or modification, this certificate is valid.

This valid certificate is available on the following Web site <http://evaluation.cstb.fr> to check its validity.

CERTIFIED CHARACTERISTICS

The products covered by the NF mark Sanitary components have the minimal characteristics required by the standards, possibly completed by the technical specifications specified in the appendix

This certificate comprises 2 pages.

Correspondent :

Stéphane FATIS
Phone : (33) 01 64 68 88 60
Fax : (33) 01 64 68 84 44
Email : stephane.fatis@cstb.fr

For CSTB
On behalf of the President


Edwige PARISEL

Appendix to the Certificate

Decision no. 269-U2-21/5

INLET VALVE

These products have the minimum characteristics defined in the NF EN 14-124 standard and in the technical documents DT076-01 and DT076-02.

CSTB	Trademark	Range	Reference	DN	Class Acou.	Lap	qm	Type of supply
UNIVERSAL INLET VALVE								
FU01a)	SIAMP	BRIO	752	3/8	I	18	0,17	SIDE SUPPLY
FU01b)	SIAMP	BRIO	752OD	3/8	I	18	0,17	SIDE SUPPLY
FU02	SIAMP	BRIO	755 OD	3/8	II	26	0,17	SIDE SUPPLY

FLUSHING MECHANISMS

These products have the minimum characteristics defined in the technical documents DT076-01 and DT076-03.

CSTB	Trademark	Range	Reference	Type	Cover boring	Flush volume (l)	Residual regulation	hmax	hmin
UNIVERSAL MECHANISM									
I01	SIAMP	classic	42	Pull botton	10-42	9/6	No	455	255
I02	SIAMP	storm	33A	Push botton	18-50	9/6	No	415	305
UNIVERSAL WATER SAVING MECHANISM									
K02a)	SIAMP	skipper	45	Push botton	38	3/6	No	468	293
K02b)	SIAMP	--	36 A	Push botton	18-50	3/6	No	468	393
K03	SIAMP	OPTIMA	49	Push botton	18-50	3/6	Yes	448	285
K04	SIAMP	BRIO	574	Push botton	18-42	3/6	Yes	445	295
K05	SIAMP	BRIO	576	Push botton	18-42	3/6	Yes	460	310