

Certificate of constancy of the performance of the product**0679-CPR-1148**

(English translation, the original version is in French)

In compliance with the Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 laying down harmonised conditions for the marketing of construction products and repealing Council Directive 89/106/EEC, it has been stated that the construction products indicated in the following page, placed on the European economic area market by:

ARCELORMITTAL CONSTRUCTION FRANCE

Zone Industrielle
Site n° 1
FR-55800 CONTRISSON

and produced in the factory:

ARCELOR MITTAL CONSTRUCTION France
1 Rue Roger Salengro
FR-59264 ONNAING

Are submitted by the manufacturer to a factory production control and to the further testing of samples taken of the factory in accordance with a prescribed test plan, and that the notified body - CSTB - has performed the assessment of the performance of the construction product, the initial inspection of the manufacturing plant and of the factory production control and performs the continuing surveillance, assessment and evaluation of the factory production control (system 1).

This certificate attests to the products performance, relative to the fire reaction chosen by the manufacturer, and that all provisions concerning the assessment and verification of constancy of this performance described in the harmonised reference technical specification:

EN 14509: 2013

are applied and that the products fulfill all the prescribed requirements.

This certificate can only be used in conjunction with the declaration of performance of the product written by the manufacturer or his authorised representative established in the European economic area and with the technical specification in reference.

This certificate is issued on 29 June 2022, it replaces the certificate previously delivered on 02 July 2019 and, except for withdrawal or suspension, remains valid as long as the conditions laid down in the corresponding technical specification in reference or the manufacturing conditions in the factory or the factory production control itself are not modified significantly.

This certificat comprises 2 pages.

The list of certificates issued by CSTB is kept up-to-date by the CSTB.

Issued in Champs sur Marne, on 29 June 2022

Par délégation
du Président

Florian RASSE

Certificate of constancy of the performance of the product

0679-CPR-1148

Self-supporting double skin metal face insulating panels with polyurethane core insulation

FRIGOTHERM AMC01 (for thicknesses between) 40 mm and 50 mm

FRIGOTHERM D AMC01 (for thicknesses between) 40 mm and 50 mm

Performance of the construction product:

Products fire reaction characteristic: B- s2, d0 (Interior and exterior faces)

Use category :

Cold Store