

**Certificate** of constancy of the performance of the product**0679-CPR-1361**

(English translation, the original version is in French)

In compliance with the Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 laying down harmonised conditions for the marketing of construction products and repealing Council Directive 89/106/EEC, it has been stated that the construction products indicated in the following page, placed on the European economic area market by:

**ARCELORMITTAL CONSTRUCTION FRANCE**

Zone Industrielle  
Site n° 1  
FR-55800 CONTRISSON

and produced in the factory:

ARCELOR MITTAL CONSTRUCTION France  
1 Rue Roger Salengro  
FR-59264 ONNAING

are submitted by the manufacturer to a factory production control and to the further testing of samples taken of the factory in accordance with a prescribed test plan, and that the notified body - CSTB - has performed the assessment of the performance of the construction product(s), the initial inspection of the manufacturing plant and of the factory production control and performs the continuing surveillance, assessment and evaluation of the factory production control (system 1).

This certificate attests to the products performances, relative to the fire reaction performance chosen by the manufacturer, and that all provisions concerning the assessment and verification of constancy of this (these) performance(s) described in the harmonised reference technical specification:

EN 14509 : 2013

are applied and that the products fulfill all the prescribed requirements.

This certificate can only be used in conjunction with the declaration of performance of the product written by the manufacturer or his authorised representative established in the European economic area and with the technical specification in reference.


This certificate is first issued on 30/06/2021 and, except for withdrawal or suspension, remains valid as long as the conditions laid down in the corresponding technical specification in reference or the manufacturing conditions in the factory or the factory production control itself are not modified significantly.

This certificat comprises 2 pages.

The list of certificates issued by CSTB is kept up-to-date by the CSTB.

Issued in Champs sur Marne, on 30/06/2022.

Par délégation  
du Président



Florian RASSE

Self-supporting double skin metal face insulating panels with polyurethane core insulation

PROMISOL S iQ + for thicknesses  $\geq 60$  mm

PROMISOL V iQ + for thicknesses  $\geq 60$  mm

FRIGOTHERM iQ + for thicknesses  $\geq 60$  mm

Performance of the construction product:

Products fire reaction characteristic: B- s1, d0 (inside and outside)

Use category :

Wall claddings (PROMISOL V iQ + et PROMISOL S iQ +) and Cold Store (FRIGOTHERM iQ +)