

Certificate of constancy of the performance of the product**0679-CPR-1318**

(English translation, the original version is in French)

In compliance with the Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 laying down harmonised conditions for the marketing of construction products and repealing Council Directive 89/106/EEC, it has been stated that the construction products indicated in the following page, placed on the European economic area market by:

ParexGroup S.A.

19, place de la résistance
CS 50053
FR-92445 ISSY-LES-MOULINEAUX

and produced in the factory:

ParexGroup S.A. – 3, avenue de la Grande Marine – FR-84800 L'ISLE SUR LA SORGUE

is submitted by the manufacturer to a factory production control and to the further testing of samples taken of the factory in accordance with a prescribed test plan, and that the notified body - CSTB - has performed the assessment of the performance of the construction product, the initial inspection of the manufacturing plant and of the factory production control and performs the continuing surveillance, assessment and evaluation of the factory production control (system 1).

This certificate attests to the product performance, relative to the fire reaction performance chosen by the manufacturer, and that all provisions concerning the assessment and verification of constancy of this performance described in the harmonised reference technical specification

European Technical Approval Guideline No 004 (ETAG 004), edition 2013
used as European Assessment Document (EAD)
completed by :

European Technical Assessment ETA-11/0110 – version 2, delivered 29/06/2018

are applied and that the product fulfills all the prescribed requirements.

This certificate can only be used in conjunction with the declaration of performance of the product written by the manufacturer or his authorised representative established in the European economic area and with the technical specification in reference.


This certificate is issued on 13th February 2023, it replaces the certificate previously delivered on 09th February 2021 and, except for withdrawal or suspension, remains valid as long as the conditions laid down in the corresponding technical specification in reference or the manufacturing conditions in the factory or the factory production control itself are not modified significantly.

This certificat comprises 2 pages.

The list of certificates issued by CSTB is kept up-to-date by the CSTB.

Issued in Champs sur Marne, on 13th February 2023.

Par délégation
du Président



Florian RASSE

Certificate of constancy of the performance of the product

0679-CPR-1318

PARISO LR - M / PAREXTHERM MW

External Thermal Insulation Composite System with powder render (ETICS)

Product fire reaction performance:

A2-s1,d0, according to the standard EN 13501-1+A1 : 2013

only valid for the following configurations :

Configuration	Declared organic content ⁽¹⁾	Declared flame retardant content ⁽¹⁾	Class according to EN 13501-1
<ul style="list-style-type: none"> • Supplementary adhesives: <ul style="list-style-type: none"> - MAITÉ - COLLE CCP+ - UNITÉ • Insulation product: Mineral wool panels, reaction to fire Class A1, thickness ≤ 300 mm, density ≤ 155 kg/m³ • Base coat: MAITÉ • Meshes: <ul style="list-style-type: none"> - R 131 A 101 C+ - R 131 A 102 C+ - SSA-1363 F+ • Key coats: <ul style="list-style-type: none"> - REVLANE+ RÉGULATEUR - SILICANE FOND + SILICANE PEINTURE - SILICANE FOND • Finishing coats: <ul style="list-style-type: none"> - EHI GM - EHI GF - MAITÉ with MARBRI GRANULATS - SILICANE TALOCHÉ FIN/GROS - CALCIFIN - CALCILISSE - MAITÉ with SILICANE PEINTURE - PAREX DÉCO TRAVERTIN⁽²⁾ - - REVLANE+ SILOXANÉ IGNIFUGÉ TG⁽²⁾ 	<p style="text-align: center;">Base coat: 7.0%</p> <p style="text-align: center;">Finishing coats: 2.6 to 11.9%</p> <p>- Except for MAITÉ (7.0%) with: - SILICANE PEINTURE (13.7%) - MARBRI GRANULATS (0.0%)</p>	<p style="text-align: center;">Base coat: 0.0%</p> <p style="text-align: center;">Finishing coats: 0.0 to 18.3%</p>	A2-s1, d0

⁽¹⁾ Percentage declared by the Manufacturer, relative to the dried weight of the component as delivered.

⁽²⁾ With or without PARITÉ+ ACCÉLÉRATEUR.

Certificate of constancy of the performance of the product

0679-CPR-1318

Product fire reaction performance:

A2-s2,d0, according to the standard EN 13501-1+A1 : 2013

only valid for the following configurations :

Configuration	Declared organic content ⁽¹⁾	Declared flame retardant content ⁽¹⁾	Class according to EN 13501-1
<ul style="list-style-type: none"> • Supplementary adhesives: <ul style="list-style-type: none"> - MAITÉ - COLLE CCP+ - UNITÉ • Insulation product: Mineral wool panels, reaction to fire Class A1, thickness ≤ 300 mm, density ≤ 155 kg/m³ • Base coat: MAITÉ • Key coat: REVLANE+ RÉGULATEUR • Meshes: <ul style="list-style-type: none"> - R 131 A 101 C+ - R 131 A 102 C+ - SSA-1363 F+ • Finishing coats: <ul style="list-style-type: none"> - REVLANE+ IGNIFUGÉ TALOCHÉ FIN/GROS⁽²⁾ - REVLANE+ IGNIFUGÉ RIBBÉ FIN⁽²⁾ - REVLANE+ SILOXANÉ IGNIFUGÉ TF/RB⁽²⁾ 	<p style="text-align: center;">Base coat: 7.0%</p> <p style="text-align: center;">- Finishing coats: 9.9 to 11.4%</p>	<p style="text-align: center;">Base coat: 0.0%</p> <p style="text-align: center;">Finishing coats: 17.5%</p>	A2-s2, d0

⁽¹⁾ Percentage declared by the Manufacturer, relative to the dried weight of the component as delivered.

⁽²⁾ With or without PARITÉ+ ACCÉLÉRATEUR.

Use category:

External insulation of "buildings' walls"

Particular conditions applicable to the use of the product:

Application on vertical walls of masonry or concrete